



PLNF-00770

Date of Notice: November 5, 2013

To: Prospective Bidders

Re: **Plainfield Police Department Emergency Generator and UPS Installation**
City of Plainfield, Union County, New Jersey
Addendum No. 2

The following is an addendum to the Bid Documents:

1. To clarify circuit requirements indicated for the 911 Call Center on drawing 3 of the Bid Documents, the Contractor will install (2) quad receptacles at each workstation in the 911 Call Center and connect to new UPS panelboard with 2#12, #12G in 3/4" C (Typ. for 5 workstations). Existing workstation receptacles and circuits in Room 8 and Printer Room to remain.
2. The fuel tank specified on drawing 2 of the Bid Documents will be made of aluminum, mounted on a Ford F-650 owned by the City of Plainfield. The City of Plainfield will drive the truck to the mechanic's location for installation. Since there is no prevailing wage for auto mechanic, it is assumed the state will not regulate those wages; however they must still be posted and reported.

Please acknowledge receipt of this addendum by signing and returning this sheet.

Very truly yours,

T&M ASSOCIATES

KEITH W. HENDERSON, P.E.
CONSULTING ENGINEER

I hereby acknowledge receipt of Addendum No. 2 herein above dated November 5, 2013

(COMPANY NAME)

BY: _____

(PRINT NAME)

(TITLE)

KWH:DJN:scb

H:\PLNF\00770\Specs\Addendum 1_PLNF-00770.doc

ENERGY & UTILITIES • ENVIRONMENTAL SERVICES • PUBLIC WORKS
REAL ESTATE DEVELOPMENT • TRANSPORTATION • WATER RESOURCES

Regional Offices in NEW JERSEY, PENNSYLVANIA and OHIO